

**DOCUMENT "A"**

**MINISTER'S DETERMINATION  
CONDITIONS OF APPROVAL**

Pursuant to Regulation 87-83 under the Clean Environment Act

**December 2, 2014**

File Number: 4561-3-1387

1. In accordance with section 6(6) of the Regulation, it has been determined that the undertaking may proceed following approval under all other applicable acts and regulations.
2. Commencement of this undertaking must occur within three years of the date of this Determination. Should commencement not be possible within this time period the undertaking must be registered under the *Environmental Impact Assessment Regulation (87-83) – Clean Environment Act* again, unless otherwise stated by the Minister of Environment and Local Government.
3. The proponent shall implement measures to require adherence by all contractors, sub-contractors and workers on this project, to all obligations, commitments, monitoring and proposed mitigation measures presented in the EIA Registration Document dated May 16, 2014, as well as all those identified in subsequent correspondence during the registration review. Additionally, the proponent must submit a summary table detailing the status of each Condition listed in this Determination to the Manager of the Environmental Assessment Section, Department of Environment and Local Government (DELG) every 6 months from the date of this Determination until such a time as all the Conditions have been met.
4. The maximum allowable pumping rate for the Prepared Food Plant (PFP) Well is 600 L/min (863 m<sup>3</sup>/day).
5. A flowmeter must be installed on the PFP Well and the water usage recorded daily (minimum 5 days/week). This information will be submitted annually to the Manager of the Environmental Assessment Section, Department of Environment and Local Government (DELG).
6. The observation well is not approved for use as a production well and will not be used for anything other than monitoring purposes.
7. If at any time the proponent wants to increase the maximum allowable pumping rate from the PFP Well, to use the observation well or requires a new water supply well, the Manager of the Environmental Assessment Section, Department of Environment and Local Government (DELG) must be contacted as additional hydrogeological testing may be required.
8. In the event that a neighbour complains that the operation of this water supply has negatively impacted (quality or quantity) their private water supply, the proponent must investigate the complaint and follow the DELG Certificate of Approval condition with respect to reporting the complaint.
9. The proponent shall ensure that all developers, contractors and operators associated with the project comply with the above requirements.

