

DOCUMENT "A"

MINISTER'S DETERMINATION CONDITIONS OF APPROVAL

Pursuant to Regulation 87-83 under the Clean Environment Act
January 16, 2017
File Number: 4561-3-1430

1. In accordance with section 6(6) of the Regulation, it has been determined that the undertaking may proceed following approval under all other applicable acts and regulations.
2. Commencement of this undertaking must occur within three years of the date of this Determination. Should commencement not be possible within this time period the undertaking must be registered under the *Environmental Impact Assessment Regulation* (87-83) – Clean Environment Act again, unless otherwise stated by the Minister of Environment and Local Government.
3. The proponent shall adhere to all obligations, commitments, monitoring and mitigation measures presented in the EIA registration document dated March 29, 2016 as well as all those identified in subsequent correspondence during the registration review. Additionally, the proponent shall submit a summary table detailing the status of each Condition listed in this Determination to the Manager of the Environmental Assessment Section of the Department of Environment and Local Government (DELG) every six months from the date of this Determination until such a time as the Manager determines it is no longer required.
4. If it is suspected that remains of archaeological significance are found during construction, as per the Heritage Conservation Act, all activity shall be stopped near the find and the Resource Manager of the Archaeological Services Unit, Heritage Branch of the Department of Tourism, Heritage and Culture, shall be contacted at (506) 453-3014.
5. The maximum allowable pumping rate for Well # 16-4 is 5 igpm (22.7 L/min) for a maximum daily withdrawal of 32.7 m³/day. The well must be equipped with a flowmeter and the volume must be recorded daily (for a minimum of five days per week). The flowmeter data must be submitted in the Annual Report as per the requirements of the *Approval to Operate*.
6. The maximum allowable pumping rate for Well # 3 is 3 igpm (13.6 L/min) for a maximum daily withdrawal of 19.6 m³/day. The well must be equipped with a flowmeter and the volume must be recorded daily (for a minimum of five days per week). The flowmeter data must be submitted in the Annual Report as per the requirements of the *Approval to Operate*.

7. Well # 16-4 must be disinfected and follow-up samples must be collected for microbiology and turbidity and submitted to DELG and the Department of Health prior to bringing the well online.
8. All proposed methods of drinking water treatment and disinfection must receive approval from the Department of Health prior to their installation and operation.
9. Well # 16-4 must be added to the *Approval to Operate* and the water system's sampling plan.
10. In the event of the sale, lease, or any other conveyance or change of control of the property, or any portion thereof, the proponent must provide written acknowledgement from the lessee, controller, or purchaser confirming that they will comply with the Conditions of this Determination to the Manager of DELG's Environmental Assessment Section.
11. The proponent must ensure that all developers, contractors, and operators associated with the construction and operation of the project comply with the above requirements.